



America

# CERTIFICATE

No. U8V 015997 0006 Rev. 00

**Holder of Certificate:** **Beluk GmbH**  
 Taubenstr. 1  
 86956 Schongau  
 GERMANY

**Production Facility(ies):** 015997

**Certification Mark:**



**Product:** **Control Equipment (Thyristor switch)**

**Model(s):** **BEL TS**  
 Type: 3TA162H2-EB22B-03

**Parameters:**

<b>Type:</b>	<b>3TA162H2-EB22B-03</b>
Rated Supply Voltage US:	120 V
Rated Input Voltage U:	480 V
Rated Input Current:	150 A
Reactive Power:	125 kvar
Rated Frequency:	50/60 Hz
Protection Class:	I

**Tested according to:** UL 508:2018

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited Certification body.

**Test report no.:** 028-713152555-000

**Date,** 2019-07-12

*(Signature)*  
 ( Abdul Sabbagh )