ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

America

CERTIFICATE

No. U8V 015997 0004 Rev. 00

Holder of Certificate: **Beluk GmbH**
Taubenstr. 1
86956 Schongau
GERMANY

Production Facility(ies): 015997

Certification Mark:

Product: **Electronic measuring equipment**

Model(s): **VarPlus Logic 6, VarPlus Logic 12, CX-Plus, CX-Plus-6T, CX-Plus-12T, CX eco**

Parameters:

Voltage measurement:
Rated frequency: 50/60Hz
Rated apparent power: 6VA
90-550V
300V LN-519VLL CAT III
550V CAT II

Current measurement:
Rated frequency: 50/60Hz
Rated apparent power: 1VA
15mA up to 5A

Tested according to:
UL 61010-1:2012/R:2015-07
CAN/CSA-C22.2 No. 61010-1:2012/U1:2015-07
UL 61010-2-030:2012
CAN/CSA-C22.2 No. 61010-2-030:2012

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. This productcertification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined inISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜDAmerica Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certificationbody.

Test report no.: 028-713057800-200

Date, 2019-03-12

(Abdul Sabbagh)

TÜV SÜD America Inc. • 10 Centennial Drive • Peabody • MA 01960 • USA